


Date: June 21, 2022

Project: **New Fire Station**
Caulfield Area Volunteer Fire Department
 US 160, Caulfield, Howell County, MO 65626
 Project Number: P19-006

Owner: **Caulfield Membership Fire Department**
 589 US 160, Caulfield, Mo 65626



This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated May 26, 2022, as described herein. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1A. MODIFICATIONS TO THE PROJECT MANUAL:

1A.01 NONE

1B. MODIFICATIONS TO THE DRAWINGS

1B.01 Sheet A2.0, Door Schedule: Change overhead doors 108A, 108B, 108C, 108D, 108F to 12' wide to match dimensions on the floor plans.

1B.02 Refer to attached Revised Light fixture schedule that includes Fixture "D".

1C. APPROVED PRODUCT SUBSTITUTIONS


Subject to compliance with the Specification requirements the product manufacturers, equipment or systems listed below are accepted as substitutes to those specified. In submitting a substitution, the contractor certifies the proposed substitution fully meets the requirements of Section 01 2500 Product Substitution Procedures. The cost of any changes in the Work resulting from a substitution shall be borne by the Contractor making the substitution. If a substitute product is found to not meet the specification requirements, the originally specified item will be provided with no change in the contract amount or construction schedule.

Section, Paragraph	Product	Approved Manufacturer
13 3400	PEMB	Reeds Metals, Scott City, Mo

1D Attachments

1D.01 E3, Revised Light fixture Schedule

END OF ADDENDUM



2022-06-17

LUMINAIRE SCHEDULE	SYMBOL	DESCRIPTION	MODEL	LAMP	BALLAST	MOUNTING	INPUT WATTS	VOLTS	NOTES	QUANTITY
A		2x4 LED TROFFER	HE WILLIAMS: AT3-24-L40840-D-DRV-UNV	(1) 43W LED	LED DRIVER	CEILING	43	120V 1P 2W	EQUALS APPROVED: LITHONIA, METALUX	9
B		4' STRIP	HE WILLIAMS: 75R-L4150/840-DRV-UNV	(1) 33W LED	LED DRIVER	SURFACE	33	120V 1P 2W	EQUALS APPROVED: LITHONIA, METALUX	6
B1		4' STRIP WITH INTEGRAL MOTION SENSOR	HE WILLIAMS: 75R-L4150/840-VDO-DRV-UNV	(1) 33W LED	LED DRIVER	SURFACE	33	120V 1P 2W	EQUALS APPROVED: LITHONIA, METALUX	2
C		8' STRIP	HE WILLIAMS: 75R-L60/840-DRV-UNV	(1) 35.3W LED	LED DRIVER	CEILING	35.3	120V 1P 2W	EQUALS APPROVED: LITHONIA, METALUX	2
D		4 FT LED LOW PROFILE INDUSTRIAL LED EMERGENCY LIGHT	HE WILLIAMS: GL4-L150/854-Q1-V8Y-UNV-ECONOLIGHT: E-XML1	(1) 90W LED (1) 1W LED	LED DRIVER	PENDANT/SURFACE	90 1	120V 1P 2W 120V 1P 2W	EQUALS APPROVED: LITHONIA, METALUX	27 2
EF1		RESTROOM EXHAUST FAN - FURNISHED AND INSTALLED BY THE MECHANICAL CONTRACTOR, DISCONNECT AND ELECTRICAL CONNECTION BY THE ELECTRICAL CONTRACTOR		(1)		CEILING	64	120V 1P 2W		2
ER		SINGLE HEAD WEATHERPROOF REMOTE EMERGENCY LIGHT - WHITE FINISH	SURE-LITES: SRP25	(1) 2.5W LED		UNIVERSAL		6V 1P 2W	EQUALS ACCEPTED, UL LISTED FOR DAMP OR WET LOCATION	2
F		SEMI-CUTOFF WALL PACK	WILLIAMS: WPAS L34	(1) 44W LED		WALL	44	120V 1P 2W	EQUALS APPROVED: LITHONIA, HUBBELL, UL LISTED FOR DAMP OR WET LOCATION	6
XE		EXIT SIGN-EMERGENCY LIGHT COMBO WITH HIGH CAPACITY (REMOTE CAPABLE) BATTERY - WHITE WITH RED LETTERS, UNIVERSAL FACE (SINGLE OR DOUBLE)	SURE-LITES LPX470RWHIDH	LED/ 5.4W INCANDESCENT WEDGE BASE	ELECTRONIC	UNIVERSAL	3	120V 1P 2W	EQUALS ACCEPTED	3

1. THE E.C. IS RESPONSIBLE TO COUNT AND CONFIRM THE QUANTITIES OF THE FIXTURES IN THE PLANS PRIOR TO ORDERING.
 2. THE E.C. IS RESPONSIBLE TO PROVIDE PHOTO-ELECTRIC CONTROLS AND LIGHTING CONTROLS IN PROPER ENCLOSURES FOR EXTERIOR LIGHTS.
 3. PROVIDE 80/100/180 CYCLE ELECTRICALLY HELED LIGHTING CONTACTORS WITH PROPER WIRING AND ENVIRONMENT PROVIDE CONTACTOR LOCATION AND ENVIRONMENT PROVIDE CONTACTOR WITH INTERNAL WIRING AND CONTROL CIRCUITS PREWIRED WITH ONLY LINE LOAD AND EXTERNAL CONTROL CIRCUITS WIRING CONNECTION REQUIRED. PROVIDE CONTACTOR WITH BUILD-IN CLEARING INTERLOCKS TO ALLOW CONTROL FROM EITHER MOMENTARY OR MAINTAINED PILOT DEVICES. CONTACTORS BY ALLEN BRADLEY, CUTLER-HAMMER, FURNAS, ITE, CHALLENGER OR SQUARE "D".

CROCKER CONSULTING ENGINEERS, INC.
 3211 E. SHADY GLEN
 SPRINGFIELD, MO 65804
 CERTIFICATE OF AUTHORITY #: E-2008010470
 ENGINEER: PATRICK D. CROCKER
 LICENSE #: E18052

NEW FIRE STATION
 CAULFIELD AREA VOLUNTEER FIRE
 DEPARTMENT
 US 160, CAULFIELD
 HOWELL COUNTY, 65626

E3
 1 OF 1